



THE NEW YORK BLOWER COMPANY
7660 Quincy Street
Willowbrook, IL 60527-5530

Visit us on the Web: <http://www.nyb.com>
Phone: (800) 208-7918 Email: nyb@nyb.com

GUIDE SPEC
GS-051
June 2007

SPECIFYING GENERAL PURPOSE FANS WITH ACOUSTAFoil® WHEEL

GENERAL

The fans shall be size _____ single-width single-inlet in Arrangement 10, capable of operating over the entire Class II range in accordance with the equipment schedule and as defined in AMCA Standard 99-20408 as designed and manufactured by The New York Blower Company. Fan wheels shall utilize non-overloading airfoil blades in all sizes. Flat, single thickness blades are not acceptable. Unless otherwise directed, fans shall be in compliance with the layout shown on the drawings.

PERFORMANCE

Fan ratings shall be based on tests made in accordance with AMCA Standard 210 and licensed to bear the AMCA Certified Ratings Seal for Air Performance. Fans not licensed to bear the AMCA Seal for performance shall be tested, at supplier's expense, in an accredited AMCA laboratory. (Option: Only AMCA certified fans will be accepted.) Fans shall have a sharply rising pressure characteristic extending throughout the operating range to assure quiet and stable operation from wide open to closed off. Fan brake horsepower shall be equal to or less than _____ BHP at _____ inches static pressure and _____ CFM at _____ density.

SOUND

Fan manufacturers shall provide sound power level ratings for fans tested and rated in accordance with AMCA Standards 300 and 301. Tests shall be performed in an accredited AMCA laboratory. Sound power ratings shall be in decibels (reference 10⁻¹² watts) in eight octave bands. Sound power levels will be corrected for installation by the specifying engineer...dBA levels only are not acceptable.

CONSTRUCTION

Fan housings are to be heavy gauge, continuously welded construction. Housings with lock seams or partially welded construction are not acceptable. Housings are to be reinforced with rigid bracing to increase structural integrity and prevent vibration. Housing inlet cones shall be aerodynamically designed and spun providing a minimum separation of air flow. Wheel diameters and outlet areas shall be in accordance with the standard dimensions adopted by AMCA for centrifugal fans. Designs not in accordance with AMCA Standard 99-240 1 are not acceptable.

BEARINGS

Bearings are to be grease lubricated, precision anti-friction ball self-aligning, pillow block design. Bearings shall be designed for a long life when rated at the fan's maximum cataloged operating speed.

SHAFT

Shafts are to be ASTM A-108 steel, grade 1040/1045, precision turned, ground and polished. Grade 1018 steel is not acceptable. The shaft's first critical speed shall be at least 120% of the fan's maximum operating speed. The drive end of the fan shaft shall be counter-sunk for tachometer readings.

PAINT

All fan surfaces are to be thoroughly prepared prior to painting using a combination of washing and hand and power tool cleaning as required. After cleaning, all surfaces are to be coated with an industrial grade coating. Surfaces of bolted components not accessible after assembly shall be coated and allowed to dry prior to final assembly. Primer only will not be accepted.

BALANCE AND RUN TEST

All fan wheels shall be dynamically balanced on precision balancers. Prior to shipment, completed fans shall receive a final test balance at the specified operating speed.

ACCESSORIES

Accessories shall be provided as in the plans and specifications.

Required accessories include:

- Cleanout Door - Quick Opening, Flush Bolted
- Spark-Resistant Construction-AMCA A - AMCA B - AMCA C
- Drain
- Drain Plug
- Flanged Outlet
- Outlet Companion Flange
- Shaft Seal, Ceramic-Felt, Buna-N, Viton®, Teflon®
- Flanged Inlet
- Inlet Companion Flange
- Inlet Box Assembly
- Inlet Box Damper
- Inlet Vane Damper - Internal, External
- Heat-Fan Construction
- Positive Screw Adjustment
- Outlet Shutter - Automatic, Motorized
- Weather Cover/Belt Guard
- Safety Equipment - Inlet Guard, Outlet Guard
- Vibration Isolation Rails - Spring, Rubber-In-Shear
- V-Belt Drive - Variable Speed, Constant Speed
- Outlet Damper - Parallel Blade, Opposed Blade

FINAL INSPECTION

All fans shall receive a final inspection by a qualified inspector prior to shipment. Inspection to include: fan description and accessories, balance, welding, dimensions, bearings, duct and base connection points, paint finish and overall workmanship.

© Registered Trademark of The New York Blower Company.

© Acoustafoil is a Registered Trademark of The New York Blower Company.

Viton and Teflon are registered trademarks of DuPont Dow Elastomers and DuPont respectively.

Form 607 GAW